Laboratory ID: 0055

National Testing Laboratories, Ltd
556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 479758

6/12/2025

Customer: C-Force
6151 Highway 90
Navasota, Texas 77868

Source: Lone Wolf Artesian Well
Source Type: Well Water
Brand Name: HEB Electrolyte
Production Code: CF 04/30/25
Container Size: 1 Liter
PWS ID#: TX 0930067

Date/Time Received: 5/6/2025 10:06
Collected by: C. Tagudin

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

pH analysis has a 15 minute hold time from sampling to analysis. Analysis of pH past the 15 minute hold time should be considered an estimate. In addition, Chlorine, Chloramine and Chlorine Dioxide hold time is immediate, therefore results should be considered an estimate.

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
				Inorganic Analytes - Metals						
1002	Aluminum	200.7	0.2	mg/L	0.05	ND	1	5/12/2025 13:46		5/30/2025
1074	Antimony	200.8	0.006	mg/L	0.003	ND	1	5/12/2025 13:46		6/3/2025
1005	Arsenic	200.8	0.010	mg/L	0.002	ND	1	5/12/2025 13:46		6/3/2025
1010	Barium	200.7	2	mg/L	0.10	ND	1	5/12/2025 13:46		5/30/2025
1075	Beryllium	200.7	0.004	mg/L	0.001	ND	1	5/12/2025 13:46		5/30/2025
1079	Boron	200.7	--	mg/L	0.10	ND	1	5/12/2025 13:46		5/30/2025
1015	Cadmium	200.7	0.005	mg/L	0.001	ND	1	5/12/2025 13:46		5/30/2025
1016	Calcium	200.7	--	mg/L	2.0	ND	1	5/12/2025 13:46		5/30/2025
1020	Chromium	200.7	0.100	mg/L	0.007	ND	1	5/12/2025 13:46		5/30/2025
1022	Copper	200.7	1.0	mg/L	0.002	ND	1	5/12/2025 13:46		5/30/2025
1028	Iron	200.7	0.3	mg/L	0.020	ND	1	5/12/2025 13:46		5/30/2025
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	5/12/2025 13:46		6/3/2025
1031	Magnesium	200.7	--	mg/L	0.10	2.00	1	5/12/2025 13:46		5/30/2025
1032	Manganese	200.7	0.05	mg/L	0.004	ND	1	5/12/2025 13:46		5/30/2025
1035	Mercury	200.8	0.002	mg/L	0.0002	ND	1	5/12/2025 13:46		6/3/2025
1036	Nickel	200.7	--	mg/L	0.005	ND	1	5/12/2025 13:46		5/30/2025
1042	Potassium	200.7	--	mg/L	1.0	2.8	1	5/12/2025 13:46		5/30/2025
1045	Selenium	200.8	0.05	mg/L	0.002	ND	1	5/12/2025 13:46		6/3/2025
1049	Silica	200.7	--	mg/L	0.05	1.30	1	5/12/2025 13:46		5/30/2025

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 479758

6/12/2025

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected		DF	Date/Time Sampled		Date Prepped	Date/Time Analyzed	
1050	Silver	200.7	0.10	mg/L	0.002	ND		1	5/12/2025	13:46		5/30/2025	
1052	Sodium	200.7	--	mg/L	1	10		1	5/12/2025	13:46		5/30/2025	
1085	Thallium	200.8	0.002	mg/L	0.001	ND		1	5/12/2025	13:46		6/3/2025	
4006	Uranium	200.8	0.030	mg/L	0.001	ND		1	5/12/2025	13:46		6/3/2025	
1095	Zinc	200.7	5.000	mg/L	0.004	ND		1	5/12/2025	13:46		5/30/2025	
						Physical Factors							
1927	Alkalinity (Total as CaCO3)	2320B	--	mg/L	20	22		1	5/12/2025	13:46		5/13/2025	
1905	Apparent Color	2120B	15	CU	3	ND		1	5/12/2025	13:46		5/13/2025	11:30
1928	Bicarbonate (as CaCO3)	2320B	--	mg/L	20	22		1	5/12/2025	13:46		5/13/2025	
1929	Carbonate (as CaCO3)	2320B	--	mg/L	20	ND		1	5/12/2025	13:46		5/13/2025	
1910	Corrosivity	2330B	--	SI		-3.11	R2	1	5/12/2025	13:46		6/3/2025	
2905	Foaming Agents	5540C	0.5	mg/L	0.1	ND		1	5/12/2025	13:46		5/12/2025	15:05
						MBAS, calculated as Linear Alkylate Sulfonate (LAS), mol wt of 342.4 g/mole							
1915	Hardness	2340B	--	mg/L	5.0	8.2		1	5/12/2025	13:46		5/30/2025	
1021	Hydroxide (as CaCO3)	2320B	--	mg/L	20	ND		1	5/12/2025	13:46		5/13/2025	
1920	Odor Temperature	2150B	--	Deg, C		20		1	5/12/2025	13:46		5/12/2025	15:05
1920	Odor Threshold	2150B	3	ton	1	ND		1	5/12/2025	13:46		5/12/2025	15:05
1925	pH	150.1	6.5-8.5	pH Units		7.3		1	5/12/2025	13:46		5/12/2025	14:50
4254	pH Temperature	150.1	--	Deg, C		21		1	5/12/2025	13:46		5/12/2025	14:50
1064	Specific Cond. @ 25 deg. C	2510B	--	umhos/cm	1	86		1	5/12/2025	13:46		5/13/2025	
1930	Total Dissolved Solids	2540C	500	mg/L	5	33		1	5/12/2025	13:46		5/16/2025	
0100	Turbidity	2130B	1	NTU	0.1	ND		1	5/12/2025	13:46		5/13/2025	11:15
						Inorganic Analytes - Other							
1011	Bromate	300.1	0.010	mg/L	0.005	ND		1	5/12/2025	13:46		5/20/2025	
1004	Bromide	300.1	--	mg/L	0.005	ND		1	5/12/2025	13:46		5/20/2025	
1006	Chloramine as Cl2	4500Cl-G	4.0	mg/L	0.05	ND		1	5/12/2025	13:46		5/12/2025	16:21
1017	Chloride	300.0	250	mg/L	1.0	14.0		1	5/12/2025	13:46		5/14/2025	12:19
1000	Chlorine - Total	4500Cl-G	--	mg/L	0.10	ND		1	5/12/2025	13:46		5/12/2025	16:21
1012	Chlorine as Cl2	4500Cl-G	4.0	mg/L	0.05	ND		1	5/12/2025	13:46		5/12/2025	16:18
1008	Chlorine Dioxide as Cl02	4500Cl02D	0.8	mg/L	0.1	ND		1	5/12/2025	13:46		5/12/2025	16:23
1009	Chlorite	300.1	1.0	mg/L	0.005	ND		1	5/12/2025	13:46		5/20/2025	
1025	Fluoride	300.0	4.0	mg/L	0.10	ND		1	5/12/2025	13:46		5/14/2025	12:19
1040	Nitrate as N	300.0	10	mg/L	0.05	ND		1	5/12/2025	13:46		5/14/2025	12:19
1041	Nitrite as N	300.0	1	mg/L	0.05	ND		1	5/12/2025	13:46		5/14/2025	12:19
1044	Ortho Phosphate	300.0	--	mg/L	2.0	ND		1	5/12/2025	13:46		5/14/2025	12:19
1055	Sulfate	300.0	250	mg/L	5.0	ND		1	5/12/2025	13:46		5/14/2025	12:19
						Organic Analytes - Trihalomethanes							
2943	Bromodichloromethane	524.2 THMs	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025	
2942	Bromoform	524.2 THMs	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025	

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 479758

6/12/2025

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled		Date Prepped	Date/Time Analyzed
2941	Chloroform	524.2 THMs	--	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2944	Dibromochloromethane	524.2 THMs	--	mg/L	0.0005	0.0006	1	5/12/2025	13:46		5/13/2025
2950	Total THMs	524.2 THMs	0.080	mg/L	0.0005	0.0006	1	5/12/2025	13:46		5/13/2025
	Organic Analytes - Haloacetic Acids										
2454	Dibromoacetic Acid	552.2 HAAs	--	ug/L	1.0	ND	1	5/12/2025	13:46	5/14/2025	5/14/2025
2451	Dichloroacetic Acid	552.2 HAAs	--	ug/L	1.0	ND	1	5/12/2025	13:46	5/14/2025	5/14/2025
2453	Monobromoacetic Acid	552.2 HAAs	--	ug/L	1.0	ND	1	5/12/2025	13:46	5/14/2025	5/14/2025
2450	Monochloroacetic Acid	552.2 HAAs	--	ug/L	1.0	ND	1	5/12/2025	13:46	5/14/2025	5/14/2025
2452	Trichloroacetic Acid	552.2 HAAs	--	ug/L	1.0	ND	1	5/12/2025	13:46	5/14/2025	5/14/2025
2456	Total HAAs	552.2 HAAs	60	ug/L	1.0	ND	1	5/12/2025	13:46	5/14/2025	5/14/2025
	Organic Analytes - Volatiles										
2986	1,1,1,2-Tetrachloroethane	524.2	--	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2981	1,1,1-Trichloroethane	524.2	0.2	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2988	1,1,2,2-Tetrachloroethane	524.2	--	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2985	1,1,2-Trichloroethane	524.2	0.005	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2978	1,1-Dichloroethane	524.2	--	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2977	1,1-Dichloroethene	524.2	0.007	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2410	1,1-Dichloropropene	524.2	--	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2420	1,2,3-Trichlorobenzene	524.2	--	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2414	1,2,3-Trichloropropane	524.2	--	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2378	1,2,4-Trichlorobenzene	524.2	0.07	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2418	1,2,4-Trimethylbenzene	524.2	--	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2968	1,2-Dichlorobenzene	524.2	0.6	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2980	1,2-Dichloroethane	524.2	0.005	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2983	1,2-Dichloropropane	524.2	0.005	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2424	1,3,5-Trimethylbenzene	524.2	--	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2967	1,3-Dichlorobenzene	524.2	--	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2412	1,3-Dichloropropane	524.2	--	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2969	1,4-Dichlorobenzene	524.2	0.075	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2416	2,2-Dichloropropane	524.2	--	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2965	2-Chlorotoluene	524.2	--	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2966	4-Chlorotoluene	524.2	--	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2030	4-Isopropyltoluene	524.2	--	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2990	Benzene	524.2	0.005	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2993	Bromobenzene	524.2	--	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2430	Bromochloromethane	524.2	--	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2214	Bromomethane	524.2	--	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2982	Carbon Tetrachloride	524.2	0.005	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025
2989	Chlorobenzene	524.2	0.1	mg/L	0.0005	ND	1	5/12/2025	13:46		5/13/2025

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 479758

6/12/2025

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected		DF	Date/Time Sampled		Date Prepped	Date/Time Analyzed
2216	Chloroethane	524.2	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2210	Chloromethane	524.2	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2380	cis-1,2-Dichloroethene	524.2	0.07	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2228	cis-1,3-Dichloropropene	524.2	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2408	Dibromomethane	524.2	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2212	Dichlorodifluoromethane	524.2	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2964	Dichloromethane	524.2	0.005	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2992	Ethylbenzene	524.2	0.7	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2246	Hexachlorobutadiene	524.2	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2994	Isopropylbenzene	524.2	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2251	Methyl Tert Butyl Ether	524.2	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2247	Methyl-Ethyl Ketone	524.2	--	mg/L	0.005	ND	R2	1	5/12/2025	13:46		5/13/2025
2248	Naphthalene	524.2	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2422	n-Butylbenzene	524.2	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2997	o-Xylene	524.2	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2963	p and m-Xylenes	524.2	--	mg/L	0.0010	ND		1	5/12/2025	13:46		5/13/2025
	Due to the limitation of EPA Method 524.2, p and m isomers of Xylene are reported as aggregate.											
2998	Propylbenzene	524.2	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2428	sec-Butylbenzene	524.2	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2996	Styrene	524.2	0.1	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2426	tert-Butylbenzene	524.2	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2987	Tetrachloroethene	524.2	0.005	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2991	Toluene	524.2	1	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2979	trans-1,2-Dichloroethene	524.2	0.1	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2224	trans-1,3-Dichloropropene	524.2	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2984	Trichloroethene	524.2	0.005	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2218	Trichlorofluoromethane	524.2	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2904	Trichlorotrifluoroethane	524.2	--	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2976	Vinyl Chloride	524.2	0.002	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
2955	Xylenes (Total)	524.2	10	mg/L	0.0005	ND		1	5/12/2025	13:46		5/13/2025
	Organic Analytes - Others											
2414	1,2,3-Trichloropropane	504.1	0.00003	mg/L	0.00001	ND		1	5/12/2025	13:46	5/19/2025	5/19/2025
2931	1,2-Dibromo-3-chloropropane	504.1	0.0002	mg/L	0.00001	ND		1	5/12/2025	13:46	5/19/2025	5/19/2025
2946	1,2-Dibromoethane	504.1	0.00005	mg/L	0.00001	ND		1	5/12/2025	13:46	5/19/2025	5/19/2025
2105	2,4-D	515.4	70	ug/L	0.1	ND		1	5/12/2025	13:46	5/15/2025	5/20/2025
2066	3-Hydroxycarbofuran	531.2	--	ug/L	1.0	ND		1	5/12/2025	13:46		6/4/2025
2051	Alachlor	525.2	2	ug/L	0.2	ND		1	5/12/2025	13:46	5/15/2025	6/10/2025
2047	Aldicarb	531.2	7	ug/L	1.0	ND		1	5/12/2025	13:46		6/4/2025
2044	Aldicarb sulfone	531.2	7	ug/L	1.0	ND		1	5/12/2025	13:46		6/4/2025
2043	Aldicarb sulfoxide	531.2	7	ug/L	1.0	ND		1	5/12/2025	13:46		6/4/2025
2356	Aldrin	505	--	mg/L	0.00007	ND		1	5/12/2025	13:46	5/19/2025	5/19/2025

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 479758

6/12/2025

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected		DF	Date/Time Sampled		Date Prepped	Date/Time Analyzed
2050	Atrazine	525.2	3	ug/L	0.1	ND		1	5/12/2025	13:46	5/15/2025	6/10/2025
2625	Bentazon	515.4	--	ug/L	1	ND		1	5/12/2025	13:46	5/15/2025	5/20/2025
2306	Benzo(A)pyrene	525.2	0.2	ug/L	0.02	ND		1	5/12/2025	13:46	5/15/2025	6/10/2025
2076	Butachlor	525.2	--	ug/L	0.2	ND		1	5/12/2025	13:46	5/15/2025	6/10/2025
2021	Carbaryl	531.2	--	ug/L	1.0	ND		1	5/12/2025	13:46		6/4/2025
2046	Carbofuran	531.2	40	ug/L	1.0	ND		1	5/12/2025	13:46		6/4/2025
2959	Chlordane	505	0.002	mg/L	0.0001	ND		1	5/12/2025	13:46	5/19/2025	5/19/2025
2031	Dalapon	515.4	200	ug/L	1	ND		1	5/12/2025	13:46	5/15/2025	5/20/2025
2035	Di(2-ethylhexyl) adipate	525.2	400	ug/L	0.2	ND		1	5/12/2025	13:46	5/15/2025	6/10/2025
2039	Di(2-ethylhexyl) phthalate	525.2	6	ug/L	0.6	ND		1	5/12/2025	13:46	5/15/2025	6/10/2025
2440	Dicamba	515.4	--	ug/L	1	ND		1	5/12/2025	13:46	5/15/2025	5/20/2025
2933	Dichloran	505	--	mg/L	0.001	ND		1	5/12/2025	13:46	5/19/2025	5/19/2025
2070	Dieldrin	505	--	mg/L	0.00002	ND		1	5/12/2025	13:46	5/19/2025	5/19/2025
2041	Dinoseb	515.4	7	ug/L	0.2	ND		1	5/12/2025	13:46	5/15/2025	5/20/2025
2032	Diquat	549.2	20	ug/L	0.4	ND		1	5/12/2025	13:46	5/13/2025	5/14/2025
2033	Endothall	548.1	100	ug/L	9	ND		1	5/12/2025	13:46	5/19/2025	5/30/2025
2005	Endrin	505	0.002	mg/L	0.00001	ND		1	5/12/2025	13:46	5/19/2025	5/19/2025
2034	Glyphosate	547	700	ug/L	6	ND		1	5/12/2025	13:46		5/23/2025
2065	Heptachlor	505	0.0004	mg/L	0.00001	ND		1	5/12/2025	13:46	5/19/2025	5/19/2025
2067	Heptachlor Epoxide	505	0.0002	mg/L	0.00001	ND		1	5/12/2025	13:46	5/19/2025	5/19/2025
2274	Hexachlorobenzene	505	0.001	mg/L	0.0001	ND		1	5/12/2025	13:46	5/19/2025	5/19/2025
2042	Hexachlorocyclopentadiene	505	0.05	mg/L	0.0001	ND		1	5/12/2025	13:46	5/19/2025	5/19/2025
2010	Lindane	505	0.0002	mg/L	0.00002	ND		1	5/12/2025	13:46	5/19/2025	5/19/2025
2022	Methomyl	531.2	--	ug/L	1.0	ND		1	5/12/2025	13:46		6/4/2025
2015	Methoxychlor	505	0.04	mg/L	0.0001	ND		1	5/12/2025	13:46	5/19/2025	5/19/2025
2045	Metolachlor	525.2	--	ug/L	0.2	ND		1	5/12/2025	13:46	5/15/2025	6/10/2025
2595	Metribuzin	525.2	--	ug/L	0.2	ND		1	5/12/2025	13:46	5/15/2025	6/10/2025
2626	Molinate	525.2	--	ug/L	0.2	ND		1	5/12/2025	13:46	5/15/2025	6/10/2025
2036	Oxamyl	531.2	200	ug/L	1.0	ND		1	5/12/2025	13:46		6/4/2025
2934	Pentachloronitrobenzene	505	--	mg/L	0.0001	ND		1	5/12/2025	13:46	5/19/2025	5/19/2025
2326	Pentachlorophenol	515.4	1	ug/L	0.04	ND		1	5/12/2025	13:46	5/15/2025	5/20/2025
2040	Picloram	515.4	500	ug/L	0.1	ND		1	5/12/2025	13:46	5/15/2025	5/20/2025
2077	Propachlor	525.2	--	ug/L	0.2	ND		1	5/12/2025	13:46	5/15/2025	6/10/2025
2110	Silvex 2,4,5-TP	515.4	50	ug/L	0.2	ND		1	5/12/2025	13:46	5/15/2025	5/20/2025
2037	Simazine	525.2	4	ug/L	0.07	ND		1	5/12/2025	13:46	5/15/2025	6/10/2025
2627	Thiobencarb	525.2	--	ug/L	0.2	ND		1	5/12/2025	13:46	5/15/2025	6/10/2025
2383	Total PCBs	505	0.0005	mg/L	0.0005	ND		1	5/12/2025	13:46	5/19/2025	5/19/2025
2910	Total Phenols	420.4	--	mg/L	0.001	ND	R2	1	5/12/2025	13:46		5/19/2025
2020	Toxaphene	505	0.003	mg/L	0.001	ND		1	5/12/2025	13:46	5/19/2025	5/19/2025
2055	Trifluralin	505	--	mg/L	0.001	ND		1	5/12/2025	13:46	5/19/2025	5/19/2025

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 479758

6/12/2025

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed

Qualifiers:

R2: The laboratory is not licensed for this parameter. The reported result cannot be used for compliance purposes.

Analyst	Tests
ZSC	200.7,2340B
DMJ	200.8,2330B
SP	2320B,2120B,5540C,2150B,150.1,2510B,2130B
CF	2540C
SG	300.1,300.0
DHG	4500Cl-G,4500Cl02D,420.4
SB	524.2 THMs,524.2,531.2,547
BNF	552.2 HAAs,504.1,515.4,505
JLF	525.2,548.1
JF	549.2

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.